

STEGE SANITARY DISTRICT

PHONE (510) 524-4668 FAX (510) 524-4697

STANDARD SEWER REHABILITATION PROJECT # 12201

ADDENDUM NO. 1

Wednesday, July 18, 2012

The following clarifications are added to the specifications for the above referenced project:

SPECIFICATIONS

REPLACE ALL references to ten (10) percent (as it refers to retention) to **five (5) percent**. (Section G9.09 RETENTION, Page GC.50)

DELETE NON-COLLUSION AFFIDAVIT (Page BP.14)

ADD INSTEAD NON COLLUSION DECLARATION. (Attached)

Please note that the new NON COLLUSION DECLARATION does not require notary public endorsement.


ADD The bid item for concrete encase pipe (Bid Item 37) shall include all work related to demolition and disposal of any existing concrete encased pipe to be re-encased as part of the work outlined in this bid item. (Section 3.1.1 MINIMUM COVER, Page 2B.5)

ADD Upon completion of any pipe bursting activity, and prior to invoicing, the Contractor shall CCTV inspect at least one full section (manhole to manhole) of existing pipe downstream of the lowest pipe replaced to ensure that no broken pipe is introduced into the sanitary sewer system that may cause blockages. If remnants of burst pipe are found during the CCTV inspection the Contractor shall inspect at least one additional section downstream of where the burst pipe or debris is found. Any burst pipe or debris found during the CCTV inspection shall be removed by the Contractor. No invoices will be processed prior to submission of the post construction CCTV inspection. (Section 1A, Item 9, DEBRIS REMOVAL FROM PIPELINE CONSTRUCTION OPERATIONS)

CLARIFICATIONS

Mobilization shall be lump sum. It shall not be "pro-rated" based on the amount of pipe installed.

STEGE SANITARY DISTRICT



Paul Soo, Jr. Assistant Engineer

7/18/2012

Date

The following are included with this ADDENDUM:

- MANDATORY PRE-BID ATTENDEES / LIST OF ELIGIBLE BIDDERS
- NON-COLLUSION DECLARATION (REPLACES NON-COLLUSION AFFIDAVIT)
- PRE-BID MEETING MINUTES OF TUESDAY, JULY 17, 2012, @ 10:00AM

STEGE SANITARY DISTRICT

PHONE (510) 524-4668 FAX (510) 524-4697

MANDATORY PRE-BID ATTENDEES

Bid opening is **Tuesday, July 24, 2010 @ 2:01 PM.**

LIST OF ELIGIBLE BIDDERS

<p>Pacific Trenchless, Inc. 1619A Campbell Street Oakland, CA 94607 pacifictrenchless@gmail.com Phone # 415/559-0983 Fax # 415/647-8166</p>	<p>D'Arey & Harty Construction, Inc. 1300 Carroll Avenue San Francisco, CA 94124 darcyharty@sbcglobal.net Phone # 415/822-5200 Fax # 415/822-0747</p>
<p>Ranger Pipelines P.O. Box 24109 San Francisco, CA 94124 estimating@rangerpipelines.com Phone # 415/822-3700 Fax # 415/822-3703</p>	<p>J. Howard Engineering Inc. 881 Moorpark St., Oakland, CA 94603 howard96@aol.com Phone # 510/639-7080 Fax # 510/639-7099</p>
<p>California Trenchless 11875 Dublin Blvd. Suite C240, Dublin, CA 94568 mjardin@californiatrenchless.com Phone # 925/361-7046 Fax # 510/266-1543</p>	<p>H&R Plumbing 3990 La Cima Rd., El Sobrante, CA 94803 horacio@handrplumbing.com frank@handrplumbing.com Phone # 510/224-0238</p>
<p>Insutraform Technologies 8620 Antelope North Rd. Antelope, CA 95843 chanson@insutraform.com Phone # 916/729-2209 Fax # 916/729-2215</p>	

STEGE SANITARY DISTRICT

PHONE (510) 524-4668 FAX (510) 524-4697

NON-COLLUSION DECLARATION

TO BE EXECUTED BY BIDDER AND SUBMITTED WITH BID

(Public Contract Code § 7106)

The undersigned declares:

I am the _____ (title) of _____ (company/contractor) the party making the foregoing bid. The bid is not made in the interest of, or on behalf of, any undisclosed person, partnership, company, association, organization, or corporation. The bid is genuine and not collusive or sham. The bidder has not directly or indirectly induced or solicited any other bidder to put in a false or sham bid. The bidder has not directly or indirectly colluded, conspired, connived, or agreed with any bidder or anyone else to put in a sham bid, or to refrain from bidding. The bidder has not in any manner, directly or indirectly, sought by agreement, communication, or conference with anyone to fix the bid price of the bidder or any other bidder, or to fix any overhead, profit, or cost element of the bid price, or of that of any other bidder. All statements contained in the bid are true. The bidder has not, directly or indirectly, submitted his or her bid price or any breakdown thereof, or the contents thereof, or divulged information or data relative thereto, to any corporation, partnership, company, association, organization, bid depository, or to any member or agent thereof, to effectuate a collusive or sham bid, and has not paid, and will not pay, any person or entity for such purpose. Any person executing this declaration on behalf of a bidder that is a corporation, partnership, joint venture, limited liability company, limited liability partnership, or any other entity, hereby represents that he or she has full power to execute, and does execute, this declaration on behalf of the bidder.

I declare under penalty of perjury under the laws of the State of California that the foregoing is true and correct and that this declaration is executed on _____ [date], at _____ [city], California.

By _____
(Signature)

Name _____
(Printed Name)

Title _____

BP.14

STEGE SANITARY DISTRICT

PHONE (510) 524-4668 FAX (510) 524-4697

STANDARD SEWER REHABILITATION PROJECT # 12201

Pre-Bid Meeting Agenda
Tuesday, July 17, 2012, @ 10:00am

1. STEGE SANITARY DISTRICT REPRESENTATIVES

- Paul Soo, Jr. [paul@stegesd.dst.ca.us] – Assistant Civil Engineer
- Arvin Gonzales [arvin@stegesd.dst.ca.us] – Construction Inspector

2. PROJECT DESCRIPTION:

- This project includes but is not limited to –
REHABILITATION OF EXISTING SANITARY SEWER PIPE BY PIPE BURST AND CURED-IN-PLACE-PIPE AT VARIOUS LOCATIONS IN EL CERRITO, KENSINGTON AND RICHMOND.
- Bids will be based on a standard sewer rehabilitation section as described in the Project Specifications. The standard section consists of:
 - *Mobilization (lump sum cost per single site).*
 - *Pipe bursting and cured-in-place-pipe*
 - *6"Ø, 8"Ø, 10"Ø and 12"Ø pipes up to 8 feet deep*
 - *Reconnect and seal pipe connections to manhole structures*
 - *Locating and reconnecting lateral connections*
- **The following REVISIONS have been incorporated to this year's spec from the previous year's project:**
 - Clarification of mobilization. One mobilization lump sum per site. (S1.09)
 - Bond increased to one million dollars (\$1,000,000).
 - Representative sewer rehabilitation section added, Right-of-Way section in addition to Easement section.
 - **Easement Section:** Includes: mobilization (CCTV inspection, excavation, bedding, backfill, compaction, surface restoration, labor, equipment, sheeting & shoring and all disposal). (S1.02)
 - **Right-of-Way Section:** Includes: mobilization (see Easement section), traffic control, public noticing, saw-cutting, utility location & protection, potholing, temporary paving and striping restoration.
 - Additional bid items based on two representative sections.
 - Manhole rehabilitation specified as Mainstay or approved equal. (Section 2B. 2.10)
 - Addition of Reinforced Concrete Manhole Frame & Cover Repair which INCLUDES mobilization in bid item price. This work shall be done independent of any main line replacement. (Section 2B. 8)
 - Addition of (sewer main) Point Repair which INCLUDES mobilization in bid item price. This work shall be done independent of any main line replacement. (Section 2B. 3.3)
 - New line items for Aggregate Base (CY), Asphalt Concrete (CY), Sidewalk Concrete Paving (CY) and Concrete Pipe Encasement (CY) (**CLARIFICATION: Encasement includes demo and disposal of (E)**).
- The standard section will be adjusted accordingly to the ratio of actual work performed. Adjustments for sections which have site conditions that require significant, additional labor to execute shall be negotiated and the price adjusted accordingly on a case-by-case basis.
- The actual lines for rehabilitation have not all been identified. The District has a Video Truck that will be identifying lines throughout the year. We anticipate a variety of lines including both easements and streets, as well as lines starting in streets and running through easements. The District will typically package approximately 1,500 - 2,000 feet per quarter.
- The Engineer's Estimate for the bid schedule total is **\$1,000,000**.

STEGE SANITARY DISTRICT

PHONE (510) 524-4668 FAX (510) 524-4697

- Each Bid must be accompanied by a Proposal Guaranty payable to the OWNER in the amount of not less than **twenty (20) percent** of the Total Base Bid.
 - The total amount to be expended by the District during the contract period shall not exceed **one million dollars (\$1,000,000)**, but may be increased by approval of the District's Board of Directors. The District makes no representation or guarantee of the minimum amount to be spent by the District.
 - The winning bidder will be required to furnish two bonds each in the amount of **one million dollars (\$1,000,000)**, one as security for the faithful performance of the work, and the other as security for the faithful payment and satisfaction of all persons furnishing materials and performing labor on the work.
 - Contract duration is for a period of three hundred and sixty five (365) calendar days from the date of the start of work designated in the "Notice to Proceed" but may be extended, by mutual agreement, between the District and Contractor for an additional three hundred and sixty five (365) calendar days.
 - Attendance at this pre-bid meeting is mandatory. Bid opening on **Tuesday, July 24, 2010 @ 2:00 PM**.
3. CONTRACTOR SAFETY STANDARDS (see attached hand-outs)
- Contractor Pre-qualification (EMR, RIR, LTIR). The project shall be contracted to the lowest *responsible* bidder. The District will determine whether a contractor is a responsible bidder based on its safety record, using three methods (see attachment): **Experience Modification Rate (EMR), Recordable Incident Rate (RIR), Lost Time Incident Rate (LTIR)**
 - Contractor Safety Orientation and Contractor Self Certification Worksheet (see attachments) to be read and completed by the **successful** bidder and submitted with signatures prior to award.
4. PROJECT DISCUSSION
- The Contractor shall take whatever measures, including the acquisition of licenses or other rights of use, which are required with respect to any such patents or intellectual property right claims and to defend, indemnify and hold the District harmless from any such patents or claims without any cost or expense to the District. (G7.12)
 - The contractor will be held responsible for the character and conduct of their employees while working on the project. (G5.13)
 - All work shall be conducted with the least possible obstruction and inconvenience to the public. (G7.16)
 - The contractor is responsible for any damage done to property during the progress of the work. (G7.18, G7.19)
 - The contractor shall keep a clean project work site. The contractor is responsible for insuring materials are stored safely and securely. All areas of work shall be left in a neat, presentable and secure condition at the end of each workday. (G4.12)
 - The contractor is responsible for obtaining encroachment permits from the City of El Cerrito, City of Richmond, and Contra Costa County for Kensington. Trenches in paved public roads shall be resurfaced in accordance with the provisions and requirements of the encroachment permit. (1A.3)
 - The Contractor shall protect the sanitary sewer line from entry of debris during progress of the work. The Contractor shall provide and install the mechanisms to trap loose debris at the next downstream manhole.(1A.9)
 - Work hours shall be from 8:00am to 5:00pm, except in Cal-Trans right-of-ways, where work hours shall be from 9:00am to 3:00pm. Contractors shall not work on weekends or District holidays. (1A.12)
5. QUESTIONS
- The deadline for questions is **Thursday, July 19, 2010, @ 2:00pm**. Questions must be provided to the District in writing by fax, email or hand delivered letter.
-